

**Posey County Building Commission**

**NOTICE**

Effective immediately, a gas pressure test report will be required prior to scheduling a final inspection. This report is to be certified by the installer as meeting all requirements of the International Fuel Gas Code (2006).

In the case of modular or sectional homes, the entire fuel gas piping system will require testing regardless of any factory testing provided.

Any gas service turned off for more than 1 year will be required to be tested.

\*\*\*\*\*

Owner: \_\_\_\_\_

Address: \_\_\_\_\_

The undersigned has personally tested the fuel gas piping system at the above location according to:

- 1) International Fuel Gas Code (2006)

Natural gas \_\_\_\_\_

Propane \_\_\_\_\_

\_\_\_\_\_  
*Signature*

\_\_\_\_\_  
*Printed Name*

\_\_\_\_\_  
*Date*

\_\_\_\_\_  
*Indiana Plumbers License#*